

NSV Energy LLC  
35 Hickory Springs Industrial Drive  
Canton GA 30115



Stock# NGR03

Avtron Neutral Ground resistor with enclosure. 7200 v volts line to neutral 50/60 hz. 100 amps 10 sec rating, 72.0 ohms, 110 kv BIL, Drawing number D29958, Cat # ANG72-1, Serial number 9906, with 50:5 ct, Instrument transformer cat #145-500, used for 13.8 kv generator, made in USA.

