

NSV Energy LLC
35 Hickory Springs Industrial Drive
Canton GA 30115



Stock # WG22

Two (2) Woodward ProTech-GII Overspeed Protection device, HV/LV, Voted relays/input, Part number: 8237-1601 REV C, Serial number 21098488, 20818669, input voltage 125 vdc or 90-264 Vac 50/60 hz, Made in USA
Shipping boxes size: 26" X 19" X 10" 36 lbs



7LLB9 **W. WOODWARD** 1711

NAME: PROTECH GII, PANEL MOUNT, HV/HV, VOTED RELAYS/ INPUTS
PART NO. 8237-1601 REV. C
SERIAL NO. 21098488

TEMPERATURE RANGE: $-20^{\circ}\text{C} \leq T_{amb} \leq 60^{\circ}\text{C}$

INPUT VOLTAGE RATING PER MODULE X 3:
INPUT #1: 90-264V \sim , 47-63 Hz, 30 WATTS MAX. CONTINUOUS
OR 100-150 V \equiv , 30 WATTS MAX. CONTINUOUS
INPUT #2: 90-264V \sim , 47-63 Hz, 30 WATTS MAX. CONTINUOUS
OR 100-150 V, 30 WATTS MAX. CONTINUOUS

USE WIRE RATED FOR MINIMUM 85°C
FOR USE IN HAZARDOUS LOCATIONS CLASS I DIV 2, GROUPS A,B,C,D T4

CE Ex II 3 G SA US REFER TO MANUAL 26709 E3740

Ex nA IIC T4 X MFD AT: 1041 WOODWARD WAY, FT. COLLINS, COLORADO 80524 U.S.A.

WARNING
- EXPLOSION HAZARD -
SUBSTITUTION OF COMPONENTS MAY IMPAIR
SUITABILITY FOR CLASS I, DIVISION 2.

AVERTISSEMENT
- RISQUE D'EXPLOSION -
LA SUBSTITUTION DE COMPOSANTS PEUT RENDRE CE MATERIEL
INACCEPTABLE POUR LES EMPLACEMENTS DE CLASSE I, DIVISION 2.

WARNING **AVERTISSEMENT**
- EXPLOSION HAZARD - DO NOT CONNECT OR DISCONNECT WHILE CIRCUIT IS LIVE
- DANGER D'EXPLOSION - NE PAS RACCORDER NI DERACLER TANT QUE LE CIRCUIT EST EN TENSION

WARNING
DO NOT REMOVE MODULES