

NSV Energy LLC
35 Hickory Springs Industrial Drive
Canton GA 30115





Stock # G31-CAP

Three (3) GE surge protection Capacitor 13800 v, 0.25 UF , 1 pole, 110 kv BIL, 60 hz, Model 9L18, Cat # 18L0009WH with DIELEKTROL Fluid, Inst GEH-2730



SIZE A	DWG NO 18L0009WH	SHT 2	REV 3
REV 3	DESCRIPTION CASE HT WAS 8.50	DATE 5/15/2009	APPROVED BTR

TOL	IN.	MM
A	.06	1.5
B	.12	3.0
C	.18	4.6
D	.25	6.4



SCHEMATIC DIAGRAM - 103

13800 VAC
.25 UF
1 POLE KVAR
CAT 18L0009WH
101N171

110 kVBIL
Hz 50/60
SN
1.1 GAL.
MFG DATE
READ GEH- 2730

GE ENERGY FORT EDWARD, N.Y., U.S.A.		DATE 10/1/1996
DRAWN	D.E.Stone	DATE 10/4/1996
ISSUED		DATE 10/4/1996

SIZE A	OUTLINE 18L0009WH	
SCALE	SHEET 2	CONT ON -

DISTR. TO